

HORIZONTALLY POSITIONED RESCUE

ACCOMMODATED IN THE PASSENGER

LITTER (7'-0" X 2'-0") SHALL BE

NOTE: DIMENSIONS INDICATED ARE

ELEVATORS MUST MEET THIS

ELEVATOR CAB FLOORING - MATCH FLOOR SELECTION OF 1ST FLOOR ELEVATOR LOBBY FLOORING

CLEAR DIMENSIONS. ALL

REQUIREMENT.

TYP. 1 HR FLOOR/CEILING ASSEMBLY

3/4" MIN. OSB OR RIMBOARD DRAFTSTOP

ACOUSTICAL SEALANT

- DOUBLE 2x TOP PLATE

- SOUND BATT INSULATION

1' - 0 1/4"

ELEVATOR DOOR FRAME

ELEVATOR DOOR FRAME

ELEVATOR CAB STRETCHER REQUIREMENT AT SERVICE CAR

SCALE: 1/2" = 1'-0"

BRG WALL ADJ. TO CMU SHAFT

HEADER TRACK

FASCIA -

HEADER COVER

HOISTWAY

DOOR HANGER (NON METALLIC -FACED ROLLERS WITH THRUST ROLLERS

9 ELEVATOR HEAD DETAIL

SCALE: 3" = 1'-0"

SCALE: 1 1/2" = 1'-0"

ELEVATOR CAB

SOUTH TERRACES 115 PERIMETER CENTER PLACE, SUITE 950 ATLANTA, GEORGIA 30346 TELEPHONE: 770 396 7248

WWW.THEPRESTONPARTNERSHIP.COM CONSULTANT

COMPLIANCE WITH ADA. <u>FINISHES</u> 1. STAINLESS STEEL FRAMES WITH BRUSHED CHROME

2. STANDARD PLASTIC LAMINATE WALLS 3. CARPET ON FLOOR 4. HIGH CAB
5. STANDARD CEILING FINISH **ELEVATOR MACHINE ROOM**

<u>HOISTWAYS</u>

ABOVE PIT FLOOR.

ELEVATOR HOISTWAY.

INSIDE OF HOISTWAY.

FLUSH WITH PIT FLOOR.

9. NOT USED

ASDFASDF

ELEVATOR CAR

SECURITY DESK.

EACH ELEVATOR CAR.

1. MINIMUM 3 SQUARE FEET VENTILATION TO OUTSIDEAIR

2. PROJECTIONS AND SETBACKS IN HOISTWAY MUST BE

3. 120V DUPLEX WATERPROOF OUTLET INSTALLED IN PIT 18"

4. INCANDESCENT LIGHT FIXTURE WITH TRASH GUARD

5. A RATE OF RISE HEAT DETECTOR INSTALLED IN EACH

6. HOISTWAY DOORS AT EACH LEVEL TO BE NUMBERED ON

7. HOISTWAYS MUST BE FREE OF WIRE TIES, NAILS, ETC.

8. SUMP PUMP WITH METAL GRATING. GRATING MUST BE

1. TWO WAY COMMUNICATION PER ADA REGULATIONS IS TO BE INSTALLED. IF TELEPHONE IS USED LINE MUST BE TO

OUTSIDE SOURCE OR TO BE MANNED 24 HOURS AT

2. 'NO SMOKING IN CAR' SIGN TO BE INSTALLED IN CAR.

3. WORKING TELEPHONE OR INTERCOM TO BE PROVIDED IN

4. ALL CAB CONTROL HEIGHTS ARE REQUIRED TO BE IN

10. THE MAXIMUM GUIDE RAIL SPAN IS 14'-0".

(PER CAR) FOR HOISTWAYS OVER 3 FLOORS.

BEVELED AT 75 DEGREES OF HORIZONTAL.

INSTALLED 18" ABOVE PIT FLOOR.

1. ELEVATOR MACHINE ROOM SHALL BE TWO-HOUR FIRE RATED, IT SHALL HAVE AN AUTOMATIC DISCONNECTING MEANS FOR ELEVATOR POWER. 2. CLASS 'C' FIRE EXTINGUISHER TO BE IN MACHINE ROOM.

3. 110VOLT AC CAR LIGHTING DISCONNECT IN MACHINE ROOM. 4. THREE-PHASE FUSED DISCONNECT OR CIRCUIT BREAKER LOCATED IN MACHINE ROOM, SHALL BE CAPABLE OF BEING

LOCKED IN THE OFF POSITION. **ELEVATOR LOBBY** 1. EACH FLOOR TO HAVE SIGN SAYING 'IN FIRE EMERGENCY -

DO NOT USE ELEVATOR USE EXIT STAIRS'

2. SMOKE SENSING DEVICE TO BE PROVIDED IN EACH ELEVATOR LOBBY AND ASSOCIATED MACHINE ROOM WHEN ELEVATOR TRAVEL EXCEEDS 25'0" ABOVE OR BELOW MAIN NOTE: THESE SMOKE SENSORS ONLY TO INITIATE

FIREMAN'S EMERGENCY RETURN. 3. FIREMAN'S EMERGENCY KEY BOX TO BE PROVIDED IN **CONTRACTOR INFORMATION**

1. RESIDENTIAL PASSENGER ELEVATORS SHALL BE RATED TO TRAVEL 150 FEET PER MINUTE FOR ALL UNITS SERVED. 2. NOT USED

3. PROVIDE ELEVATOR CAB PROTECTION PADS FOR EACH

PARTNERSHIP, LLC A MULTI-DISCIPLINARY DESIGN FIRM

FAX: 770 396 2945



RESERVE AT THE BALLPARK, PHASE II, AKA REVEL AT THE BALLPARK 2885 CRESCENT PKWY SMYRNA, GA 30080



ATLANTIC REALTY **PARTNERS**

3438 PEACHTREE ROAD **SUITE 1425** ATLANTA, GA 30326

ISSUES & A- REVISIONS	DATE
CONCEPTUAL DESIGN	08/21/2015
SCHEMATIC DESIGN	09/28/2015
GMP/DESIGN DEVELOPMENT	10/15/2015
GMP	04/03/2017
PERMIT SET	05/22/2017
3 BUILDING PERMIT	07/25/2017

05/22/2017 1493101 EKS/NB Checker SHEET TITLE

ELEVATOR DETAILS

A7-25

BUILDING PERMIT RE-SUBMISSION © 2017 The Preston Partnership, LLC