

Statement of Special Inspections

Project: CIRCLE 75 PHASE II PARKING DECK
Location: Atlanta, GA
Owner: Atlantic Realty Partners
Owner's Address: 3378 Peachtree Rd NE
Atlanta, GA 30326

Architect of Record: The Preston Partnership, LLC
Structural Engineer of Record: M2 Structural, LLC

This statement of Special Inspections is submitted as a condition for permit issuance in accordance with the 2012 International Building Code w/ 2014 Georgia amendments. It includes a Schedule of Special Inspection Services applicable to this project.

The Special Inspections Engineer of Record shall keep record s of specified special inspections and testing and shall furnish copies of inspection and testing reports to the building official and to the appropriate registered design professionals of record. Discrepancies from the approved plans and specification an d code violations observed during the conduct of special inspections services shall be brought to the immediate attention of the contractor for correction and to the attention of the appropriate registered design professionals of record. A Final Report of Special Inspections documenting completion of specified special inspections and correction of any discrepancies and observed code violations noted in the inspection and testing reports shall be submitted periodically at a frequency agreed upon by the perm it applicant and the building official prior to the start of work.

Statement of Special Inspections

Project: CIRCLE 75 PHASE II PARKING DECK

Schedule of Special Inspection Services

The following sheets comprise the re quired schedule of special inspections for this project. The construction divisions which require special inspections for this project are as follows:

- ☒ Soils and Foundations

☒ Cast-in-Place Concrete

☒ Precast Concrete

☒ Masonry

☒ Finish System

☒ Structural Steel
- ☐ Cold-Formed Steel

☐ Spray Fire Resistant

☐ Wood Construction

☐ Exterior Insulation and

☐ Special Cases

Inspection Agents	Firm	Address
-------------------	------	---------

1. Special Inspector

2. Testing Laboratory

3. Other

Note: The qualifications of all personnel per forming Special Inspection activities are subject to the approval of the Building Official.

The inspection and testing agent shall be engaged by the Owner or the Owner's Agent, and not by the Contractor or Subcontractor whose work is to be inspected or to sted. Any conflict of interest must be disclosed to the Building Official, prior to commencing work.

The credentials of all Inspectors and testing technicians shall be provided if requested.

It is recommended that the person administering the Special Inspections program be a Professional Engineer experienced in the design of buildings.

Key for Minimum Qualifications of Inspection Agents (where indicated on Schedules)	
PE	Professional Engineer
EIT	Engineering in Training
ACI	American Concrete Institute Certified Concrete Field Testing Technician
AWS	American Welding Society Certified Welding Inspector
ASNT	American Society of Non - Destructive Testing - Level II or III

Qualifications of inspection agents may be indicated on the Schedule in instances where the Structural Engineer deems such requirements are appropriate.

Statement of Special Inspections

Schedule of Special Inspection Services
Soils and Foundations
Project: CIRCLE 75 PHASE II PARKING DECK

Item	Agent No. (Qualif.)	Scope
1. Shallow Foundations	1 & 2) PE or EIT	Verify that unsuitable materials are removed and that subgrade conforms to requirements of the project soils report. Verify that steel reinforcement, and accessories & embedded materials are placed in accordance with the Contract Documents and approved shop drawings. Verify that the depth and width of footings and turn downs are in conformance with contract documents.

2. Controlled Structural Fill	1 PE or EIT	Inspect compacted fill operations to verify that fill material, lift heights, level of compaction are in conformance with the requiremnts of the project soils report..
-------------------------------	-------------------	---

Statement of Special Inspections

Schedule of Special Inspection Services
Cast-in-Place Concrete
Project: CIRCLE 75 PHASE II PARKING DECK

Item	Agent No. (Qualif.)	Scope
1. Mix Design	1 EIT	Review for compliance with Contract Documents and ACI 301.
2. Material Certification	2 PE	Review for compliance with Contract Documents and ASTM.
3. Reinforcement Installation	2 EIT or ACI	Review the size, grade, spacing, location, cover and con dition of the reinforcing steel for compliance with the structural contract documents and the approved shop drawings.
4. Post - Tensioning Operations	2 EIT or ACI	Verify that post-tensioning operations are performed in strict accordance with the Cont ract Documents, Approved Shop Drawings and PTI including, but not limited to: initial stressing, elongation reports, and anchorages.
5. Batching Plant	N/A	
6. Formwork Geometry	2 EIT or ACI	Review geometry for compliance with the structural contract documents.
7. Concrete Placement	2 ACI	Inspect the placement of concrete for compliance with the structural contract documents. Test slump and temperature of each batch and verify conformance with contract docu ments. Test air content when compressive strength specimens are molded. Verify that hot and cold weather concreting is in conformance with ACI 305R and 306R when required, respectively.
8. Evaluation of Concrete Strength	2 ACI	Perform testing in a accordance with ACI 318 Sections 3.1 & 3.8. Obtain minimum 1 set of 4 cylinders for each compressive strength test. Test one specimen 7 days, 2 at 28 days and retain one in reserve for later testing if required. Perform minimum one test for every

Statement of Special Inspections

Schedule of Special Inspection Services Masonry			Project: CIRCLE 75 PHASE II PARKING DECK
Item	Agent No. (Qualif.)	Scope	
1. Material Certification	2 EIT	Review certificates of compliance for masonry units; mortar mix designs and strength tests; grout mix designs and strength tests; and manufacturer's catalog data for joint reinforcing and metal accessories.	
2. Mixing of Mortar and Grout	2 ACI	Verify mortar and grout meet standards & strength set in the contract documents and ACI 530.	
3. Installation of Masonry	2 ACI	Verify concrete masonry units (CMU) are installed properly and within plumbness tolerances as established in ACI 530.	
4. Reinforcement Installation	2 ACI or EIT	Review the size, grade, spacing, cover and condition of the reinforcing steel for compliance with the structural contract documents and the approved shop drawings.	
5. Grouting Operations	2 ACI	Verify all cells below grade with reinforcing are grouted solid full height. Inspect the placement of grout (including grout vibration)for conformance with ACI 530.1.88, Section 4.3.3, and the construction documents.	
6. Weather Protection	2 ACI	Cover top of unfinished masonry works to protect it from the weather. Verify the implementation of hot and cold weather procedures listed in Section 1.8 of ACI - 530.1 - 08/ASCE 6 - 08/TMS 602 - 08 " Specification for Masonry Structures." Implement procedures at temperatures and wind speeds listed in the above referenced section.	
7. Evaluation of Masonry Strength	2 ACI	Verify CMU meets or exceeds strength specified in the contract documents.	
8. Anchors and Ties	2 EIT	Verify that installation of anchors and ties are in conformance with design documents and ACI 530.	

Statement of Special Inspections

Schedule of Special Inspection Services
Structural Steel
Project: CIRCLE 75 PHASE II PARKING DECK

Item	Agent No. (Qualif.)	Scope
1. Fabricator Certification/ Quality Control Procedures	2 PE or AWS	Verify that the fabricator maintains detailed fabrication and quality control procedures which conform to the requirements of the American Institute of Steel Construction's Quality Certification Program.
2. Material Certification	2 PE & AWS	(1) Review mill certificates for plates and shapes. Review weld manufacturer's certificate of compliance for weld filler metal. (2) Verify bolt identification markings.
3. Open Web Steel Joists	N/A	
4. Bolting	2 PE or EIT	Inspect installation of high strength bolts for conformance with the "Specification for Structural Joints Using ASTM A325 of A490 Bolts" by the Research Council on Structural Bolts, and the construction documents.
5. Welding	2 AWS	Perform visual inspection of all welds in accordance with AWS D1.1. Perform visual inspection of metal deck welding in accordance with AWS D1.3. Perform ultrasonic testing of all groove welds. Submit welder qualification statements.
6. Shear Connectors	N/A	
7. Structural Details	2 EIT	Verify that the general geometry and elevation of the erected steel frame conforms to the construction documents and the approved shop drawings.
8. Metal Deck	2 EIT	Verify that the general geomet ry and elevation of metal deck conforms to the construction documents and the approved shop drawings

Statement of Special Inspections

Schedule of Special Inspection Services
Precast Concrete
Project: CIRCLE 75 PHASE II PARKING DECK

Item	Agent No. (Qualif.)	Scope
1. Shop Fabrication	2 EIT	Verify that application of the prestressing forces is in accordance with the procedures provided in ACI 318: 18.20. Verify the grouting of bonded prestressing tendons in the seismic force-resisting system per ACI 318: 18.18.4. (continuous)
2. Erection	2 EIT	Verify that the plans and details in the structural and precast design documents have been implemented at the required locations. Refer to ACI 318: Ch. 16. Perform inspections of welding and bolting are in accordance with section 1705.2.

Statement of Special Inspections

Schedule of Special Inspection Services
References
Project: CIRCLE 75 PHASE II PARKING DECK

- ACI 318 - 08, Building Code Requirements for Structural Concrete , Chapter 3.

• ACI 318 - 08, Building Code Requirements for Structural Concrete , § 7.4, 7.5, 7.6 and 7.7.

• ACI 318 - 08, Building Code Requirements for Structural Concrete , § 18.18.

• ACI 318 - 08, Building Code Requirements for Structural Concrete , Chapter 4 and § 5.2, 5.3, 5.4 and 5.8.

• ACI 318 - 08, Building Code Requirements for Structural Concrete , § 5.9 and 5.10.

• ACI 318 - 08, Building Code Requirements for Structural Concrete , § 5.6.

• ACI 318 - 08, Building Code Requirements for Structural Concrete , § 5.11, 5.12 and 5.13.

• ACI 301 - 08, Specifications for Structural Concrete

• ACI 305R, Hot Weather Concreting

• ACI 306R, Cold Weather Concreting


• PTI Design manual, 5th Edition

• ASCE, Standard Guidelines for the Design and Installation of Pile Foundations

• AISC, Load and Resistance Factor Design Specification for Structural Steel Buildings

• AISC, Specification for Structural Steel Buildings - Allowable Stress Design and Plastic Design

• AWS, Structural Welding Code - Steel



THE PRESTON
PARTNERSHIP, LLC
A MULTI-DISCIPLINARY DESIGN FIRM

SOUTH TERRACES
115 PERIMETER CENTER PLACE, SUITE 950
ATLANTA, GEORGIA 30346
TELEPHONE: 770.396.7248
FAX: 770.396.2945

WWW.THEPRESTONPARTNERSHIP.COM

CONSULTANT

m2
STRUCTURAL
887 West Marietta St. NW
Suite T103
Atlanta, GA 30318
www.m2structural.com
404-829-2612

SEAL



PROJECT

REVEL AT THE
BALLPARK

2885 CRESCENT PKWY
SMYRNA, GA 30080

FOR



ATLANTIC REALTY
PARTNERS

3438 PEACHTREE ROAD, SUITE 1425
ATLANTA, GA 30326
404-591-2900

DATE

SCHEMATIC DESIGN SET	08/28/2015
DD PROGRESS SET	10/07/2015
DD/CMF	10/15/2015
FOUNDATION PERMIT	12/07/2015
75% CDs	01/28/2016
GMP SET	04/03/2017
PERMIT SET	05/22/2017

DATE

JOB NUMBER

DRAWN BY

CHECKED BY

SHEET TITLE

PARKING DECK SPECIAL
INSPECTIONS

SHEET NUMBER

SP0-02

COMMENTS

RELEASED FOR CONSTRUCTION